


LYCAN 5000

Power Box

RPB48350A-48LFPA12S

VERSION A1



USER MANUAL

Applicability

The User Manual applies to the following product:

- LYCAN 5000 Power Box (RPB4835OA-48LFPA12S)

Disclaimer

- Renogy makes no warranty as to the accuracy, sufficiency, or suitability of information in the User Manual because continuous product improvements are going to be made.
- Renogy assumes no responsibility or liability for losses or damages, whether direct, indirect, consequential, or incidental, which might arise out of the use of information in the User Manual.
- Renogy is not responsible or liable for the failures, damages, or injuries resulting from repair attempted by unqualified personnel or improper installation and operation.
- The illustrations in the User Manual are for demonstration purposes only. Details may appear slightly different depending on product revision and market region.
- Renogy reserves the right to change the information in the User Manual without notice.

Copyright

LYCAN 5000 Power Box User Manual © 2022 Renogy. All rights reserved.

All information in the User Manual is subject to copyright and other intellectual property rights of Renogy and its licensors. The User Manual may not be modified, reproduced, or copied, in whole or in part, without the prior written permissions of Renogy and its licensors.

Trademarks

The following are trademarks or registered trademarks of Renogy in the United States and other countries:

RENOGY	RENOGY
--------	---------------

All other trademarks in the User Manual are the property of their respective owners and their use herein does not imply sponsorship or endorsement of their products or services. The unauthorized use of any trademark displayed in the User Manual or on the product is strictly prohibited.

Date and Revision

March 2022, Revision A1

Table of Contents

Important Safety Information	05
Symbols Used	05
General Safety Information	05
Introduction.....	07
Introduction	07
Key Features.....	07
Package Contents	09
Product Overview	10
Wiring Diagram.....	12
Installation	13
Preparation.....	13
Installation	14
Environment Requirements.....	17
Turning On.....	18
Charging	20
AC Charging.....	20
Solar Charging	21
Powering Appliances	23
Temporary Power Supply	23
Off-Grid Living	25
Emergency Backup	29
Bluetooth Pairing	35
Checking Operation Status.....	38
Checking Solar Inverter Charger Operation Status.....	38
Checking Battery Operation Status.....	43

Parameter Settings.....	45
Operations.....	45
Setting Menu.....	47
Turning Off.....	49
Capacity Expansion.....	51
Temperature Conditioning.....	54
Cooling Fan.....	54
Built-In Heater.....	54
Maintenance.....	55
Inspection.....	55
Cleaning.....	55
Storage.....	55
Emergency Responses.....	57
Fire.....	57
Flooding.....	57
Usual Smell.....	57
Usual Noise.....	57
Technical Support.....	58
Technical Specifications.....	59
Dimensions.....	61
Product Schematic.....	62
Serviceable Parts.....	63

Important Safety Information

Symbols Used General Safety Information

The User Manual provides important installation, operation, and maintenance instructions for LYCAN 5000 Power Box. Please read the User Manual carefully before installation and operation and save it for future reference. Failure to observe the instructions or precautions in the User Manual can result in electrical shock, serious injury, or death, or can damage LYCAN, potentially rendering it inoperable. The installation and service of LYCAN might require knowledge of high voltage electricity and is recommended to be carried out by qualified personnel.

Symbols Used

The following symbols are used throughout the User Manual to highlight important information:



WARNING

Indicates a potentially dangerous condition which could result in injury or death.



CAUTION

Indicates a critical procedure for safe and proper installation and operation.



NOTE

Indicates an important step or tip for optimal performance.



INFO

Indicates that more information is available in other documents relating to the subject.

General Safety Information



WARNING

- DO NOT puncture, drop, crush, penetrate, shake, strike, or step on LYCAN.
- DO NOT open, dismantle, repair, tamper with, or modify the components in LYCAN.
- DO NOT touch the connector contacts and electrical outlets on LYCAN.
- DO NOT insert foreign objects into LYCAN.
- Please remove all connections and turn LYCAN off before maintenance or cleaning.
- Please install LYCAN in accordance with the regulations at the site of installation.
- DO NOT expose LYCAN to direct flame.
- Please keep LYCAN away from heating equipment.
- Please adhere to the requirements of cable size, outlet rating, and device rating in the User Manual.
- DO NOT touch the exposed electrolyte or powder if the batteries inside LYCAN are damaged.
- DO NOT use LYCAN with life support equipment or other medical equipment.
- DO NOT connect the AC output of LYCAN to the grid.

Important Safety Information

Symbols Used

General Safety Information

- Please keep LYCAN out of the reach of young children.
- Please use insulated tools when working on or around LYCAN.
- DO NOT wear jewelry or other metal objects when working on or around LYCAN.
- Please wear proper protective equipment when working on or around LYCAN.
- DO NOT dispose of LYCAN as household waste. Please use recycling channels in accordance with local, state, and federal regulations.



CAUTION

- Please use suitable handling equipment for safe transportation of LYCAN.
- DO NOT expose LYCAN to flammable or harsh chemicals or vapors.
- Ensure that no water sources are above or near LYCAN, including downspouts, sprinklers, or faucets.
- Ensure that snow does not accumulate around LYCAN.
- DO NOT lean on, stack anything on top of, or hang anything from LYCAN or from cables leading to LYCAN.

Introduction

Introduction Key Features

Introduction

LYCAN 5000 Power Box is an all-in-one energy storage system specially designed to supply power during emergencies, power outages, or to provide power for off-grid homes. With a 4.8KWh capacity and a 3500W pure sine wave AC output, the LYCAN can deliver reliable power to most home appliances. It has a 4400W solar input capability and an intelligent maximum power point tracking (MPPT) algorithm, allowing maximized solar energy generation at any time of the day and full charge in as short as 2.5 hours. Fast AC charging, means that the LYCAN fully charges with AC power from a wall outlet or a generator in as short as 3 hours. Simultaneously connecting the LYCAN to both solar panels and AC outlets can further shorten the charging time to 1 hour from 0% to 80%. The pass-through function allows the LYCAN to bypass AC power to run home appliances while keeping its batteries topped off. Thanks to the pre-wired design and plug-n-play connectors, the LYCAN can be easily integrated into existing electric power systems, greatly reducing installation time and labor cost. The built-in circuit breakers protect the LYCAN from damage caused by unexpected system faults. Equipped with a Bluetooth module, the LYCAN provides access to real-time monitoring on the Renogy DC Home app. It can also be easily expanded to up to 19.2KWh with Renogy 48V 50Ah Smart Lithium Iron Phosphate Batteries, covering any applications from short term blackout protection to long term off-grid living. The LYCAN features a rain cap, rubber seals, and rugged enclosure, protecting against harsh outdoor environments. Built with easily-replaceable components, the LYCAN makes simple repair and maintenance possible.

Key Features

- **Massive Capacity**

Delivers long lasting power to home appliances with the 4.8KWh battery capacity.

- **Reliable Battery**

Brings incredible safety and an exceptional life span of more than 4,500 cycles with state-of-the-art lithium iron phosphate batteries.

- **Powerful Output**

Runs most heavy-duty appliances with the 3500W pure sine wave AC output.

- **Record-Breaking Charging Speed**

Full charge in 2.5 hours with solar panels, in 3 hours with AC outlets, and in 1.3 hours with both solar and AC.

- **Pass-Through Charging**

Bypasses AC power to home appliances while keeping the battery fully charged and ready for power outages.

- **Born For Integration**

Integrates to existing electric power systems easily with the pre-wired design and plug-n-play connectors.

Introduction

Introduction

Key Features

- **Built-In Protection**

Provides reliable protections and quick disconnect.

- **Seamless Expansion**

Expansion capability of up to 19.2KWh capacity.

- **Bluetooth Embedded**

Comes with Bluetooth module for real-time operation status monitoring via the Renogy DC Home App.








- **Designed For Outdoor**

Can withstand harsh outdoor environments with rain cap, rubber seals, and rugged enclosure.


- **Excellent Serviceability**

Makes repair and maintenance simple with replaceable components.

Package Contents


<p>LYCAN 5000 Power Box × 1</p>	<p>Quick Guide × 1</p>
 <p>A detailed line drawing of the LYCAN 5000 Power Box. It is a rectangular metal enclosure with a handle on top and four casters at the bottom. The front panel features a control panel with a digital display and several buttons, and a side panel with multiple ports and connectors.</p>	 <p>A line drawing of the Quick Guide booklet. The cover features the RENOGY logo, the product name 'LYCAN 5000 Power Box', the model number 'RPB48350A-48LFAI25', and a small image of the power box. The text 'QUICK GUIDE' is printed at the bottom.</p>
<p>Keys × 2</p>	<p>RJ45 Plug Waterproof Housing × 1</p>
 <p>A line drawing of two keys. One is a standard metal key with a notched bit, and the other is a square key with a circular head.</p>	 <p>A line drawing of a cylindrical RJ45 plug waterproof housing. It has a textured outer surface and a central opening for the plug.</p>
<p>Handle Bar × 1</p>	<p>Handle Bar Screws × 4</p>
 <p>A line drawing of a handle bar. It consists of a horizontal cylindrical bar with two vertical support legs. The legs are attached to the bar with screws.</p>	<p>M8x1.25x20mm</p>  <p>A line drawing of four screws. They are M8x1.25x20mm screws with a hexagonal head and a Phillips-style cross-shaped recess.</p>
<p>IEC C19 to NEMA 5-20P Power Cable × 1</p>	
 <p>A line drawing of a power cable. It has an IEC C19 connector on one end and a NEMA 5-20P connector on the other. The cable is coiled.</p>	

Product Overview




No.	Part	No.	Part
1	Solar Inverter Charger Display (Including Indicators and Buttons)	8	Viewing Window
2	Solar Input Circuit Breaker 1	9	Bluetooth Module
3	Solar Input Circuit Breaker 2	10	AC Output Circuit Breaker (20A)
4	Battery Circuit Breaker	11	AC Output Circuit Breaker (30A)
5	Surge Protection Device	12	AC Input Circuit Breaker (20A)
6	Front Door Locks	13	AC Outlet (30A)
7	AC Inlet (20A)	14	AC Outlet (20A)

Product Overview



No.	Part	No.	Part
15	Solar Connector 1	20	Grounding Hole
16	Solar Connector 2	21	Gray Anderson 120 Connector (Including Dust Cover)
17	Handle Bar (Pre-Installed)	22	RJ45 Jack (Including Waterproof Housing)
18	Back Door Locks	23	Vent Cover
19	Handle Bar (Installation Required)	24	Swivel Casters

Wiring Diagram




Installation

Preparation

Installation

Environment Requirements

Preparation




1. Inspect LYCAN for any visible damages including cracks, dents, deformation, and other visible abnormalities before installation. The connector contacts and electrical outlets shall be dry, clean, and free of any dirt and corrosion.




WARNING

- DO NOT use LYCAN if it appears damaged.



2. Find the Keys zip tied to the Handle Bar.




3. Open the Back Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the back door.

Installation

Preparation

Installation

Environment Requirements



4. Inspect the batteries inside LYCAN for any visible damages including cracks, dents, deformation, and other visible abnormalities before installation.




WARNING

- DO NOT use LYCAN if the batteries inside appear damaged.
- Please close the back door, rotate the wing knobs clockwise by 90°, and lock the Back Door Lock after inspecting the batteries inside LYCAN.

Installation

Required Tools and Accessories

Phillips Screwdriver (#2)	Wrench (10mm)	Wrench (12mm)	Grounding Cable




1. Find the Handle Bar and the Handle Bar Screws under LYCAN.

Installation


Preparation

Installation


Environment Requirements



2. Install the Handle Bar on the left side of LYCAN with the Handle Bar Screws. Make sure that the Screws are firmly tightened with the Philips Screwdriver.



3. Loosen the screws to remove the fixing brackets from LYCAN. Keep the upper screws properly for subsequent grounding cable connection.



4. Lift LYCAN from the skid with two people.



WARNING


- Lycan is heavy and can cause injury if not handled properly.
- Please ensure that the Handle Bar is installed firmly on LYCAN before lifting.

Installation

Preparation

Installation

Environment Requirements




5. Release the Pedal Brakes on Swivel Casters. Move LYCAN to a proper installation location.




CAUTION

- If transporting the Swivel Casters over wet surfaces, ensure water is not deeper than 2 inches (50.8mm).



6. Engage the Pedal Brakes on Swivel Casters to prevent LYCAN from moving.




7. Connect the ring terminal of a grounding cable (not included) to the grounding hole of LYCAN with the screws removed from the fixing bracket.

Installation

Preparation

Installation

Environment Requirements



8. Connect the bare wire end of the grounding cable to a grounding rod (not included).



CAUTION

- Please secure the grounding cable connections to the proper specification.
- Please use 4AWG or larger grounding cable.

Environment Requirements

LYCAN shall be installed at ground level on a flat surface. Ensure that the installation environment is clean, cool, ventilated, and away from oil, dirt, and direct sunlight. Allow at least 1 foot (0.3 m) of space behind the Vent Cover for efficient heat dissipation. Safe operation requires ambient temperatures between 14°F (-10°C) and 122°F (50°C).



CAUTION

- Operating LYCAN at temperatures outside its specified range might cause irreversible damage to LYCAN.
- If LYCAN is installed in a garage, please keep it out of the driving path.




NOTE


- The maximum input/output power might decline if LYCAN operates at high temperatures above 104°F (40°C).

Turning On


LYCAN is off when it leaves the factory. Turn LYCAN on before charging it or using it to power appliances.




1. Open the Front Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the front door.



2. Push the switch up to close the Battery Circuit Breaker.




3. Rock the switch on the bottom of the solar inverter charger to the ON position (I) to turn on the solar inverter charger.




4. Open the Back Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the back door.

Turning On



5. Press and hold the power button on the top of either of the batteries for 1 second to turn on the batteries.



6. The indicators on the top of the batteries flash green. The POWER indicator of the Bluetooth module lights up green. The buzzer of the solar inverter charger beeps briefly, and the Solar Inverter Charger Display turns on.

WARNING

- Please close the front door and back door, rotate the wing knobs clockwise by 90°, and lock the Front Door Lock and Back Door Lock after turning LYCAN on.


Charging

AC Charging

Solar Charging

LYCAN supports both AC charging and solar charging, which can be combined for a faster charging speed.

AC Charging




1. Connect LYCAN to a wall outlet or a generator (not included) with the included Power Cable.




CAUTION

- The wall outlet or the outlet on the generator **MUST** be rated at 20A.
- If the 20A outlet is not available, please plug the Power Cable to a 15A outlet with a NEMA 5-20R to NEMA 5-15P plug adapter (not included) and adjust the maximum AC input current of the solar inverter charger to 15A. Refer to the Parameter Settings section for more information.




2. Loosen the captive screws to open the Viewing Window.



3. Push the switch up to close the AC Input Circuit Breaker.

Charging

AC Charging Solar Charging




- The Solar Inverter Charger Display shows that the battery is being charged by AC, and the Solar Inverter Charger CHARGE Indicator flashes green.

i NOTE

- Please close the Viewing Window and tighten the captive screws after LYCAN starts charging.

Solar Charging



- Connect the solar panels (sold separately) in series and/or parallel to form solar arrays. Connect the solar arrays to the Solar Connectors of LYCAN. LYCAN can accept up to 2 solar arrays.

! WARNING

- Each solar string needs to be protected with an appropriately sized fuse or circuit breaker.
- Please install the solar panels in accordance with the regulations at the site of installation. Additional protection devices including DC ground fault circuit interrupters, DC arc fault circuit interrupters, and rapid shutdown devices (not included) may be required.

! CAUTION

- The operating voltage of the solar array shall exceed 60VDC, the open circuit voltage shall NOT exceed 150VDC, and the short circuit current shall NOT exceed 20A.
- Please make sure that the 2 solar arrays have the same operating voltage and are not partially shaded. Operating voltage mismatches or partial shading can cause current backflow and damage solar arrays.


Charging

AC Charging


Solar Charging

i NOTE


- The solar branch connectors, solar branch adapter cables, or combiner boxes (not included) might be required to connect multiple solar strings in parallel.



2. Loosen the captive screws to open the Viewing Window.



3. Push the switch up to close the corresponding Solar Input Circuit Breaker.



4. The Solar Inverter Charger Display shows that the battery is being charged by solar, and the Solar Inverter Charger CHARGE Indicator flashes green.

i NOTE

- Please close the Viewing Window and tighten the captive screws after LYCAN starts charging.

Powering Appliances

Temporary Power Supply

Off-Grid Living

Emergency Backup

LYCAN can power appliances at temporary sites, in permanent off-grid homes, and during emergencies with Power Strips, AC Load Centers, and Transfer Switches respectively. Please refer to the corresponding instructions based on actual applications.






CAUTION

- Please fully charge LYCAN prior to first use.

Temporary Power Supply

Recommended Accessories

*Power Strip (20A Current Rating)	*Power Strip (30A Current Rating)
	



1. Connect the Power Strips (not included) with corresponding current ratings to the 20A and 30A AC Outlets of LYCAN. Plug appliances into the Power Strips.



CAUTION


- If the appliances are powered by LYCAN through the 20A AC Outlet, the continuous loads shall not exceed 16A, and the noncontinuous loads shall not exceed 20A.
- If the appliances are powered by LYCAN through the 30A AC Outlet, the continuous loads shall not exceed 24A, and the noncontinuous loads shall not exceed 30A.
- If the appliances are powered by bypass AC from a 20A outlet, the continuous loads shall not exceed 16A, and the noncontinuous loads shall not exceed 20A, no matter which AC outlet on LYCAN is used.
- If the appliances are powered by bypass AC from a 15A outlet, the continuous loads shall not exceed 12A, and the noncontinuous loads shall not exceed 15A, no matter which AC outlet on LYCAN is used.

Powering Appliances


Temporary Power Supply

Off-Grid Living

Emergency Backup



2. Loosen the captive screws to open the Viewing Window.




3. Push the switch up to close the corresponding AC Output Circuit Breaker.

Powering Appliances

Temporary Power Supply

Off-Grid Living

Emergency Backup





- The Solar Inverter Charger AC/INV Indicator lights up yellow when the appliances are powered by bypass AC. The Solar Inverter Charger AC/INV Indicator flashes yellow when the appliances are powered by LYCAN.

NOTE

- Please close the Viewing Window and tighten the captive screws after LYCAN starts powering appliances.

Off-Grid Living

Recommended Accessories

*AC Load Center and AC Circuit Breakers	*NEMA TT-30P to Bare Wire Adapter Cable
	

WARNING


- For a safe and reliable installation, it is recommended that the installation be carried out by a trained and licensed electrician.
- Please read the user manual of the AC Load Center carefully before installation.

Powering Appliances


Temporary Power Supply

Off-Grid Living


Emergency Backup



1. Remove the cover of the AC Load Center (not included). Connect the 2 live terminals with a copper busbar (not included).



2. Connect the bare wire end of the Adapter Cable (not included) to the AC Load Center. The black live wire goes to either of the live terminals (L), the white neutral wire goes to the neutral busbar (N), and the green ground wire goes to the grounding busbar (PE).



3. Size AC Circuit Breakers (not included) based on the current ratings and types of the appliances. Install the AC circuit Breakers in the AC Load Center. Connect the appliances to the AC Load Center. The black live wires go to AC Circuit Breakers, the white neutral wires go to the neutral busbar (N), and the green ground wires go to the grounding busbar (PE).

Powering Appliances

Temporary Power Supply


Off-Grid Living

Emergency Backup




CAUTION


- The AC Circuit Breakers and the appliances MUST be rated at 120VAC.
- If the appliances are powered by LYCAN, the continuous loads shall not exceed 24A, and the noncontinuous loads shall not exceed 30A.
- If the appliances are powered by bypass AC from a 20A outlet, the continuous loads shall not exceed 16A, and the noncontinuous loads shall not exceed 20A.
- If the appliances are powered by bypass AC from a 15A outlet, the continuous loads shall not exceed 12A, and the noncontinuous loads shall not exceed 15A.



4. Connect the plug end of the Adapter Cable to the 30A AC Outlet of LYCAN.



5. Replace the cover to the AC Load Center. Push the switches toward the center of the AC Load Center to close all the AC Circuit Breakers.




6. Loosen the captive screws to open the Viewing Window.

Powering Appliances


Temporary Power Supply

Off-Grid Living

Emergency Backup



7. Push the switch up to close the 30A AC Output Circuit Breaker.



8. The Solar Inverter Charger AC/INV Indicator lights up yellow when the appliances are powered by bypass AC. The Solar Inverter Charger AC/INV Indicator flashes yellow when the appliances are powered by LYCAN.

NOTE

- Please close the Viewing Window and tighten the captive screws after LYCAN starts powering appliances.

Powering Appliances



Temporary Power Supply

Off-Grid Living

Emergency Backup

Emergency Backup


Recommended Accessories

*Reliance Controls 306A Pro/ Tran 2 Manual Transfer Switch	*NEMA TT-30P to NEMA L14-30R Adapter Cable
	




WARNING

- For a safe and reliable installation, it is recommended that the installation be carried out by a trained and licensed electrician.
- Please read the user manual of the Transfer Switch carefully before installation.



1. Push the switches toward the sides of the AC load center to open all the AC circuit breakers. Remove the cover of the AC load center.




2. Connect the bare wires from the Transfer Switch (sold separately) to the AC load center. The white neutral wire goes to the neutral busbar (N), and the green ground wire goes to the grounding busbar (PE).

Powering Appliances


Temporary Power Supply

Off-Grid Living

Emergency Backup



3. Determine the 120VAC circuits that need to be used during an emergency. Disconnect the black live wires from the corresponding AC branch circuit breakers.



4. Find the red and black wires from the Transfer Switch that are marked C, D, E, and F. Connect the red wires to the selected AC branch circuit breakers. Insert the black wires marked the same letter and the black live wires disconnected from the AC branch circuit breakers into wire connectors (not included). Twist the wire connectors tightly.

CAUTION


- ONLY connect the Transfer Switch to 120VAC circuits in the AC load center.
- The current ratings of the AC circuit breakers in the Transfer Switch shall not exceed the current ratings of the corresponding AC branch circuit breakers in the AC load center.
- With a pre-installed double-pole AC branch circuit breaker, the circuits A and B of the Transfer Switch shall not be connected to the 120VAC circuits of the AC load center. If more 120VAC circuits are needed during an emergency, please replace the double-pole AC branch circuit breaker on the circuits A and B with 2 single-pole AC branch circuit breakers and remove the handle tie from the corresponding circuit selector switches. Refer to the user manual of the Transfer Switch for more instructions.
- The continuous loads shall not exceed 24A, and the noncontinuous loads shall not exceed 30A.

Powering Appliances


Temporary Power Supply

Off-Grid Living


Emergency Backup




5. Remove the cover and the power inlet filler plate of the Transfer Switch.



6. Connect the green ground wire (included in the Transfer Switch) to the grounding terminal of the Transfer Switch.



7. Replace the cover to the Transfer Switch. Run the bare wires inside the Transfer Switch through the power inlet mounting hole. Connect the bare wires to the power inlet (included in the Transfer Switch). The green ground wire goes to the G terminal, the white neutral wire goes to the W terminal, the black and red live wires go to the X and Y terminals. Tighten the terminal screws on the side of the power inlet.




8. Mount the power inlet onto the Transfer Switch.

Powering Appliances


Temporary Power Supply

Off-Grid Living


Emergency Backup




9. Replace the cover to the AC load center. Push the switches up to close all the AC circuit breakers in the Transfer Switch. Push the switches toward the center of the AC load center to close all the AC circuit breakers in the AC load center.



10. Connect the 30A AC Outlet of LYCAN to the power inlet of the Transfer Switch with the Adapter Cable (sold separately).



11. Twist the receptacle end of the Adapter Cable clockwise to lock it into place.




12. Loosen the captive screws to open the Viewing Window.

Powering Appliances


Temporary Power Supply

Off-Grid Living


Emergency Backup




13. Push the switch up to close the 30A AC Output Circuit Breaker.



14. Move all the circuit selector switches on the Transfer Switch to the LINE position.



15. During an emergency, determine the circuits to be powered by LYCAN, and move the corresponding circuit selector switches on the Transfer Switch to the GEN position.



16. The Solar Inverter Charger Display shows that the appliances are powered by LYCAN, and the Solar Inverter Charger AC/INV Indicator flashes yellow.

Powering Appliances

Temporary Power Supply

Off-Grid Living

Emergency Backup


NOTE

- The Manual Transfer Switch requires the selected circuits to be manually switched from grid to LYCAN during an emergency. If LYCAN is to be operated as an uninterruptible power supply (UPS), please use an automatic transfer switch instead.
- Please leave LYCAN plugged into a wall outlet at all times to keep it topped off and ready to power appliances during an emergency.
- Please close the Viewing Window and tighten the captive screws after LYCAN starts powering appliances.


Bluetooth Pairing

NOTE


- Please scan the QR code on the last page of the User Manual to download the DC Home app.



1. Open the Back Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the back door.




2. Locate the communication hub.




3. Unplug either of the Ethernet cables connected to the secondary communication ports of the communication hub.

Bluetooth Pairing




4. Open the DC Home app, Click "+" to search for new devices. Wait for a few minutes until a new device is found. Click "Confirm" to add the newly found device to the device list.



5. Plug the Ethernet cable back into the secondary communication port of the communication hub. Unplug the other Ethernet cable.




6. Open the DC Home app, Click "+" to search for new devices. Wait for a few minutes until a new device is found. Click "Confirm" to add the newly found device to the device list.




7. Plug the Ethernet cable back into the secondary communication port of the communication hub.

Bluetooth Pairing



8. Swipe down to refresh the device list.



9. The LINK indicator of the Bluetooth Module flashes blue.


Checking Operation Status

Checking Solar Inverter Charger Operation Status


Checking Battery Operation Status

Checking Solar Inverter Charger Operation Status


Operations



1. Loosen the captive screws to open the Viewing Window.



2. The Solar Inverter Charger Display and Indicators indicate the operation status of the solar inverter charger.














3. Press the Solar Inverter Charger UP and DOWN Buttons to turn the page and view detailed operation information.

Checking Operation Status

Checking Solar Inverter Charger Operation Status

Checking Battery Operation Status










Display Symbols

Symbol	Description
	Indicates that the solar inverter charger is connected to the AC Outlet
	Indicates that the solar inverter charger is in the wide voltage AC input mode
	Indicates that the solar inverter charger is connected to the solar arrays
	Indicates the battery level of LYCAN <div style="display: flex; flex-direction: column; align-items: center;"> <div style="display: flex; align-items: center; margin-bottom: 5px;">  Li 0%-24% </div> <div style="display: flex; align-items: center; margin-bottom: 5px;">  Li 25%-49% </div> <div style="display: flex; align-items: center; margin-bottom: 5px;">  Li 50%-74% </div> <div style="display: flex; align-items: center;">  Li 75%-100% </div> </div>
CHARGING	Indicates that LYCAN is being charged
	Indicates that the charger circuit of the solar inverter charger is active
	Indicates that the inverter circuit of the solar inverter charger is active
	Indicates that the solar inverter charger is supplying AC voltage

Checking Operation Status

Checking Solar Inverter Charger Operation Status



Checking Battery Operation Status

Symbol	Description
	<p>Indicates the load level of LYCAN</p> <p>  0%-24%  25%-49%  50%-74%  75%-100% </p>
OVER LOAD	Indicates that solar inverter charger is overloaded
BYPASS	Indicates that the loads are powered by bypass AC
	Indicates that the buzzer of the solar inverter charger is disabled
	Indicates that the solar inverter charger is in warning mode
ERROR	Indicates that the solar inverter charger is in fault mode
	Indicates that the solar inverter charger is in parameter setting mode
	<p>Indicates the error code when the solar inverter charger is not in parameter setting mode</p> <p>Indicates the currently set parameter number when the solar inverter charger is in parameter setting mode</p>
ECO	Indicates that the solar inverter charger is in power saving mode
AC	Indicates the AC charger circuit

Checking Operation Status

Checking Solar Inverter Charger Operation Status

Checking Battery Operation Status

Symbol	Description
PV	Indicates the solar charger circuit
INV	Indicates the inverter circuit
INPUTBATTEMP 	Indicates the battery voltage, battery charge current, battery charge power, solar charger temperature, solar input voltage, AC input frequency, AC input voltage, AC input current, AC charger/inverter temperature, input bus voltage, application version, model battery voltage rating, and model solar input voltage rating
OUTPUTBATLOAD 	Indicates the battery discharge current, battery discharge power, solar output current, solar output power, AC input apparent power, AC output voltage, AC output frequency, AC output current, AC output power, AC output apparent power, bootloader version, model AC output power rating, model solar output current rating

Display Menu

Page	Left Information	Middle Information	Right Information
1	Battery Voltage	Error Code	AC Output Voltage
2	Solar Charger Temperature		Solar Output Power
3	Solar Input Voltage		Solar Output Current
4	Battery Charge Current		Battery Discharge Current
5	Battery Charge Power		Battery Discharge Power
6	AC Input Frequency		AC Output Frequency
7	AC Input Voltage		AC Output Current
8	AC Input Current		AC Input Apparent Power
9	Input Bus Voltage		AC Output Apparent Power
10	AC Charger/Inverter Temperature		AC Output Power
11	Application Version		Bootloader Version
12	Model Battery Voltage		Model AC Output Power Rating
13	Model Solar Input Voltage Rating		Model Solar Output Current Rating

Checking Operation Status

Checking Solar Inverter Charger Operation Status

Checking Battery Operation Status

Error Code

Error Code	Error Name
1	Battery Undervoltage Warning
2	Battery Overcurrent Software Protection
3	Battery Not Detected Warning
4	Battery Undervoltage Protection
5	Battery Overcurrent Hardware Protection
6	Battery Overvoltage Protection
7	Battery Boost Circuit Overvoltage Hardware Protection
8	Battery Boost Circuit Overvoltage Software Protection
9	Solar Input Overvoltage Protection
10	Solar Buck Circuit Overcurrent Software Protection
11	Solar Buck Circuit Overcurrent Hardware Protection
12	Grid Power Loss Warning
13	Bypass Overload Protection
14	Inverter Overload Protection
15	Inverter Overcurrent Hardware Protection
17	Inverter Short Circuit Protection
18	Bypass Overcurrent Software Protection
19	Solar Buck Circuit High Temperature Protection
20	Inverter High Temperature Protection
21	Fan Failure
22	EEPROM Failure
23	Model Setting Error
26	Bypass Short Circuit Protection
29	Battery Boost Circuit Failure

Checking Operation Status

Checking Solar Inverter Charger Operation Status

Checking Battery Operation Status

Indicator Description

Indicator	Color	Pattern	Description
AC/INV	Yellow	Solid	Indicates that the loads are powered by bypass AC
		Flash	Indicates that the loads are powered by LYCAN or solar
CHARGE	Green	Flash	Indicates that LYCAN is being charged
FAULT	Red	Solid/Flash	Indicates that the solar inverter charger is in warning/fault mode



NOTE

- Please close the Viewing Window and tighten the captive screws after checking the operation status of the solar inverter charger.




INFO


- LYCAN might not be operating properly and needs troubleshooting if the Solar Inverter Charger Display does not turn on, or the Solar Inverter Charger FAULT Indicator lights up/ flashes red. Please refer to the user manual of the solar inverter charger at renogy.com for troubleshooting instructions.

Checking Battery Operation Status

Operations



1. Open the Back Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the back door.



2. The indicators on the top of the batteries indicate the operation status of the batteries.

Checking Operation Status

Checking Solar Inverter Charger Operation Status

Checking Battery Operation Status

Indicator Description

Color	Pattern	Description
Green	Slow Flash	Indicates that the battery is idle
	Fast Flash	Indicates that the battery is discharging
	Solid	Indicates that the battery is being charged or fully charged
Yellow	Flash	Indicates that the battery is in warning mode due to battery undervoltage or battery cell undervoltage
	Solid	Indicates that the battery is in warning mode due to charge overcurrent or discharge overcurrent
Red	Flash	Indicates that the battery is in protection mode due to battery undervoltage, battery cell undervoltage, or battery overvoltage
	Solid	Indicates that the battery is in protection mode due to charge overcurrent, discharge overcurrent, high temperature, low temperature, or short circuit



WARNING

- Please close the back door, rotate the wing knobs clockwise by 90°, and lock the Back Door Lock after checking the operation status of the batteries.



INFO

- LYCAN might not be operating properly and needs troubleshooting if the indicators of the batteries do not light up or light up/flash red. Please refer to the user manual of the battery at renogy.com for troubleshooting instructions.


Parameter Settings

Operations


Setting Menu

The solar inverter charger is preset to operate with the batteries. While no additional programming is required, some parameters can be modified for specific applications.


Operations



1. Loosen the captive screws to open the Viewing Window.



2. Press the Solar Inverter Charger SET Button to enter the parameter setting mode.




3. Press the Solar Inverter Charger UP and DOWN Buttons to select the parameters.


Parameter Settings

Operations


Setting Menu




4. Press the Solar Inverter Charger ENT Button to confirm the selection.



5. Press the Solar Inverter Charger UP and DOWN Buttons to set the parameter.



6. Press the Solar Inverter Charger ENT Button to confirm the setting.



7. Press the Solar Inverter Charger SET Button to exit the parameter setting mode.

Parameter Settings

Operations

Setting Menu

Setting Menu

Parameter Code	Parameter Name	Default Setting	Setting Range
00	Exit	ESC	ESC
01	Load Operating Mode	Utl	SOL/Utl/SBU
02	AC Output Frequency	60Hz	Modification Not Allowed
03	AC Input Voltage Range	UPS	Modification Not Allowed
04	Battery to Utility Setpoint	45.2V	42V-47.6V
05	Utility to Battery Setpoint	54.8V	48V-54.8V
06	Battery Charging Mode	SnU	Cso/Cub/SnU/oSo
07	Maximum Charging Current	100A	0A-100A
08	Battery Type	L15	Modification Not Allowed
09	Boost Charge Voltage	54V	Modification Not Allowed
12	Battery Undervoltage Load Disconnect	44.8V	Modification Not Allowed
13	Battery Undervoltage Load Disconnect Delay Time	30	Modification Not Allowed
14	Battery Undervoltage Alarm	45.6V	Modification Not Allowed
15	Battery Discharge Limit	42.8V	Modification Not Allowed
22	Power Saving Mode	dIS	Dis/EnA
23	Overload Auto Restart	EnA	Dis/EnA
24	Overtemperature Auto Restart	EnA	Dis/EnA
25	Buzzer Alarm	EnA	Dis/EnA
26	Input Source Change Alarm	EnA	Dis/EnA
27	Overload Bypass	EnA	Dis/EnA
28	Maximum AC Charging Current	40A	0A-40A
29	Split Phase	dIS	Modification Not Allowed
35	Battery Undervoltage Disconnect Recover	50.4V	Modification Not Allowed
36	Maximum Solar Charging Current	80A	0A-80A

Parameter Settings

Operations

Setting Menu

Parameter Code	Parameter Name	Default Setting	Setting Range
37	Battery Boost Return Setpoint	50.8V	Modification Not Allowed
38	AC Output Voltage	120V	Modification Not Allowed
39	Maximum AC Input Current	20A	5A-20A



CAUTION

- Modifying the parameters outside the specified range can lead to irreversible damage to LYCAN and voids the warranty.




INFO


- Please refer to the user manual of the solar inverter charger for detailed explanation of the parameters.

Turning Off


If LYCAN is not going to be used for a long time, and neither solar nor AC power are available to keep LYCAN topped off, turn LYCAN off to prevent it from overdischarging.




1. Disconnect all the cables from LYCAN.



2. Open the Front Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the front door.




3. Rock the switch on the bottom of the solar inverter charger to the OFF position (O) to turn off the solar inverter charger. The Solar Inverter Charger Display turns off, and the Solar Inverter Charger Indicator goes out after a short delay.




4. Push the switches down to open all the circuit breakers.


Turning Off



5. Open the Back Door Locks with the included Keys and rotate the wing knobs counterclockwise by 90° to open the back door.



6. Press and hold the power button on the top of the upper battery for 3-5 seconds to turn off the batteries.



7. The indicators of the battery and the Bluetooth module go out.







WARNING

- Please close the front door and back door, rotate the wing knobs clockwise by 90° , and lock the Front Door Lock and Back Door Lock after turning LYCAN off.

Capacity Expansion

If necessary, additional batteries can be connected to the Anderson Connector of LYCAN for capacity expansion.


Required Accessories

Renogy 48V 50Ah Smart Lithium Iron Phosphate Battery	Gray Anderson 120 Connector to Ring Terminal Adapter Cable
	
Battery Cables	Ethernet Cables
	



CAUTION

- ONLY connect Renogy 48V 50Ah Smart Lithium Iron Phosphate Batteries to LYCAN for capacity expansion. Connecting other brands or models of batteries to LYCAN can damage LYCAN and/or the Batteries.
- Please read the user manual of 48V 50Ah Smart Lithium Iron Phosphate Battery on renogy.com carefully before connecting additional Batteries to LYCAN.
- DO NOT connect more than 6 Batteries to LYCAN.
- DO NOT short the terminals the Batteries. Short Circuit can damage the Batteries.
- The Anderson Connectors are color coded. DO NOT mate the Anderson Connectors with different colors together.




1. Connect the Batteries (sold separately) in parallel with the Battery Cables (sold separately).

Capacity Expansion

CAUTION


- Please use 4AWG or larger Battery Cables.
- Please ensure equal length of the Battery Cables to make the batteries operate equally together.




2. Connect the UP communication ports of the latter Batteries to the LINK communication ports of the former one with the Ethernet Cables (not included).

CAUTION

- Please use CAT5 or above Ethernet Cables.



3. Remove the Dust Cover of the Anderson Connector.




4. Connect the positive and negative terminals of the first Battery to LYCAN with the Adapter Cable (not included).

Capacity Expansion



CAUTION

- Please verify the polarity before the connection. Reversed polarity can damage LYCAN and/or the Batteries.
- Please use 4AWG or larger Adapter Cable.




5. Install the included RJ45 Plug Waterproof Housing on one end of the Ethernet Cable.




CAUTION

- Please use CAT5 or above Ethernet Cables.



6. Connect the UP communication port of the first Battery to the RJ45 Jack of LYCAN with the Ethernet Cable.



7. Screw the RJ45 Plug Waterproof Housing into the Waterproof Housing of the RJ45 Jack.



NOTE


- Please repeat the Bluetooth Pairing procedures to pair the newly connected Batteries with the DC Home app.

Temperature Conditioning


Cooling Fan

Built-In Heater

Cooling Fan



The fans are located at the bottom of LYCAN. They start operating when the temperature of the air vent rises above 131°F (55°C) and stop operating when the temperature of the air vent drops below 113°F (45°C).



The thermostat is located next to the fan and displays the temperature of the air vent.

CAUTION

- The parameters of thermostat have been preset. No additional parameter setting is required.
- DO NOT modify the parameters of thermostat. Modifying the parameters can lead to irreversible damage to LYCAN and voids the warranty.

Built-In Heater

The batteries are equipped with built-in heaters. The built-in heaters start operating when the battery temperature drops below 5°C (41°F) and the charge current is greater than 6A. The built-in heater stops operating when the battery temperature rises above 10°C (50°F) or the charge current is less than 6A.

Maintenance

Inspection

Cleaning

Storage

Inspection

Please perform regular inspections following the steps below.

- Examine the external appearance of LYCAN. The enclosure and connector contacts of LYCAN shall be clean, dry, and free of corrosion.
- Check the external cables and connections. Replace any damaged cables and tighten any loose connections.



NOTE

- In some applications, corrosion can form around the contacts internal to the Anderson Connector. The corrosion can cause loosening of spring retention force and increase of mated contact resistance, leading to premature failure of the connection. Please apply dielectric grease onto each connector contact at regular intervals. Dielectric grease can repel moisture and protect the connector contact against corrosion.

Cleaning

Please clean LYCAN at regular intervals following the steps below.

- Disconnect all the cables from LYCAN.
- Turn LYCAN off.
- Clear the leaves, debris, and dust from the fans of LYCAN.
- Clean the enclosure and connector contacts of LYCAN with a soft, lint-free cloth. The cloth can be dampened with water or mild soap and water if LYCAN is extremely dirty.
- Dry LYCAN with a soft, lint-free cloth.
- Keep the area around LYCAN clean.
- Turn LYCAN back on.
- Reconnect the cables to LYCAN.

Storage

Please follow the tips below to ensure that LYCAN emerges from storage in a good condition.

- Charge LYCAN to 30%-50% and turn it off before storage.
- Ensure that the front door and back door are locked, and the Viewing Window is closed.
- Store the battery in an open, well ventilated, dry, clean area with temperatures between 32°F~104°F (0°C~40°C).
- Engage the Pedal Brakes on Swivel Casters to prevent LYCAN from moving.
- Handle LYCAN carefully to avoid sharp impacts or extreme pressure on the enclosure.
- Charge LYCAN at least once every 3 months to prevent it from overdischarging.
- Fully charge LYCAN when it is taken out of storage.
- Keep the Keys properly.

Maintenance

Inspection

Cleaning

Storage



CAUTION

- DO NOT expose LYCAN to extreme temperatures above 140°F (60°C).
- DO NOT expose LYCAN to heat sources or direct sunlight.



NOTE

- If the Keys are lost, please contact us for help.

Emergency Responses

Fire Flooding Usual Smell Usual Noise

In the event of any threat to health or safety, always begin with the steps below before addressing other suggestions.

- Immediately contact the fire department or other relevant emergency response team.
- Notify all people who might be affected and ensure that they can evacuate the area.



WARNING

- ONLY perform the suggested actions below if it is safe to do so.

Fire

1. Disconnect all the cables from LYCAN.
2. Turn LYCAN off.
3. Put out the fire with a fire extinguisher. Acceptable fire extinguishers include water, CO₂, and ABC.



WARNING

- DO NOT use type D (flammable metal) fire extinguishers.

Flooding

1. Stay out of the water if any part of LYCAN, transfer switch, AC load center, or cable is submerged.
2. Disconnect all the cables from LYCAN.
3. Turn LYCAN off.
4. If possible, protect LYCAN by finding and stopping the source of the water and pumping water away.

Usual Smell

1. Disconnect all the cables from LYCAN.
2. Turn LYCAN off.
3. Ensure that nothing is in contact with LYCAN.
4. Ventilate the room.

Usual Noise

1. Disconnect all the cables from LYCAN.
2. Turn LYCAN off.
3. Ensure that nothing is in the vent or in the fans.

Technical Support

For additional support, contact the Renogy technical support team through [renogy.com/contact-us](https://www.renogy.com/contact-us). Have the following information available when contacting Renogy.

- Owner name
- Contact information
- Order number
- Purchase channel
- Serial number
- Brief description of the issue


Technical Specifications

General	
Dimension	32.9 x 20.0 x 28.5 inch / 835 x 508 x 724 mm
Weight	264.6 lbs. / 120 kg
Operating Temperature Range	14°F~122°F / -10°C~50°C
Operating Relative Humidity Range	5%~95%
Storage Temperature Range	32°F~104°F / 0°C~40°C
Expansion Connector	Anderson 120 Connector, RJ45 Female Connector
Expansion Capability	19.2KWh
Bluetooth Range	82 ft. / 25 m
Self Consumption	25W (Power Saving Mode)
Enclosure Security	Keyed Cam Lock
Installation Environment	Indoor/Outdoor
Protection Rating	IP55
Cooling Method	Fan
Battery	
Battery Type	Lithium Iron Phosphate
Nominal Battery Voltage	48VDC
Rated Battery Capacity	100Ah
Rated Battery Energy	4.8KWh
Cycle Life	4500 Cycles (80% DOD, 80% EOL, 0.2C, 25°C)
Input	
Rated AC Input Voltage	110VAC/120VAC
Rated AC Input Frequency	50Hz/60Hz
Maximum AC Bypass Current	20A
Maximum Battery Charge Current (AC)	40A
Solar Input Voltage Range	60VDC~145VDC
Solar MPPT Voltage Range	60VDC~115VDC
Maximum Solar Input Power	4400W


Technical Support

Maximum Battery Charge Current (Solar)	80A
Maximum Battery Charge Current (Total)	100A
Output	
Rated AC Output Voltage	120VAC
Rated AC Output Frequency	50Hz/60Hz (Adjustable)
Rated Output Power	3500W
Peak AC Output Power	7000W

Dimensions



Product Schematic



Serviceable Parts

Part Number	Description
RIV4835CSH1S	48V 3500W Solar Inverter Charger
RBT50LFP48S	48V 50Ah Smart Lithium Iron Phosphate Battery
RCM-BT2	BT-2 Bluetooth Module
RCM-HUB	Communication Hub
2.16.0032	125A 1P Battery Circuit Breaker
2.16.0036	32A 1P Solar Input Circuit Breaker
2.16.0037	20A 2P AC Input/Output Circuit Breaker
2.16.0038	30A 2P AC Output Circuit Breaker
2.16.0039	40KA 2P Surge Protection Device
2.16.0051	DIN Rail End Clip
2.16.0052	4AWG 550mm Battery Interconnect Power Cable (Red)
2.16.0053	4AWG 550mm Battery Interconnect Power Cable (Black)
2.16.0056	4AWG 360mm Battery to Battery Circuit Breaker Cable (Red)
2.16.0057	4AWG 620mm Battery Circuit Breaker to Solar Inverter Charger Cable (Red)
2.16.0058	4AWG 850mm Battery to Solar Inverter Charger Cable (Black)
2.16.0059	10AWG 850mm Solar Connector 1 to Solar Input Circuit Breaker 1 Cable (Red)
2.16.0063	10AWG 400mm Solar Input Circuit Breaker 1 to Positive Busbar Cable (Red)
2.16.0060	10AWG 500mm Solar Connector 1 to Negative Busbar Cable (Black)
2.16.0061	10AWG 850mm Solar Connector 2 to Solar Input Circuit Breaker 2 Cable (Red)
2.16.0064	10AWG 400mm Solar Input Circuit Breaker 2 to Positive Busbar Cable (Red)
2.16.0062	10AWG 500mm Solar Connector 2 to Negative Busbar Cable (Black)
2.16.0065	10AWG 360mm Positive Busbar to Solar Inverter Charger Cable (Red)
2.16.0066	10AWG 480mm Positive Busbar to Solar Inverter Charger Cable (Black)
2.16.0067	4AWG 480mm Positive Busbar to Surge Protection Device Cable (Red)
2.16.0068	4AWG 480mm Negative Busbar to Surge Protection Device Cable (Black)
2.16.0069	4AWG 330mm Surge Protection Device to Grounding Busbar Cable (Yellow Green)
2.16.0070	10AWG 860mm Solar Inverter Charger to AC Output Circuit Breaker Branch Cable (Red)
2.16.0071	10AWG 880mm Solar Inverter Charger to AC Output Circuit Breaker Branch Cable (Black)
2.16.0083	10AWG 440mm Solar Inverter Charger to Grounding Busbar Cable (Yellow Green)
2.16.0072	10AWG 570mm 20A AC Output Circuit Breaker to 20A AC Outlet Cable (Red)
2.16.0073	10AWG 610mm 20A AC Output Circuit Breaker to 20A AC Outlet Cable (Black)
2.16.0074	10AWG 390mm 20A AC Outlet to Grounding Busbar Cable (Yellow Green)
2.16.0075	10AWG 480mm 30A AC Outlet Circuit Breaker to 30A AC Outlet Cable (Red)
2.16.0076	10AWG 440mm 30A AC Outlet Circuit Breaker to 30A AC Outlet Cable (Black)
2.16.0077	10AWG 270mm 30A AC Outlet to Grounding Busbar Cable (Yellow Green)
2.16.0078	10AWG 300mm 20A AC Input Circuit Breaker to 20A AC Inlet Cable (Red)
2.16.0079	10AWG 300mm 20A AC Input Circuit Breaker to 20A AC Inlet Cable (Black)
2.16.0080	10AWG 1060mm 20A AC Inlet to Grounding Busbar Cable (Yellow Green)

Product Schematic

Part Number	Description
2.16.0081	10AWG 760mm 20A AC Input Circuit Breaker to Solar Inverter Charger Cable (Red)
2.16.0082	10AWG 760mm 20A AC Input Circuit Breaker to Solar Inverter Charger Cable (Black)
2.16.0054	4AWG Battery to Anderson 120 Connector Cables
RSR28COMC-RLO5B	500mm Battery Interconnect Communication Cable
	500mm Battery to Communication Hub Cable
	1200mm Solar Inverter Charger to Communication Hub Cable
	500mm Battery to RJ45 Jack Communication Cable
RSR20AO-RLO5B	20A AC Outlet
RSR20AOC-RLO5B	20A AC Outlet Cover
RSR30AO-RLO5B	30A AC Outlet
RSR30AOC-RLO5B	30A AC Outlet Cover
RSR20AI-RLO5B	20A AC Inlet
RSR20AIC-RLO5B	20A AC Inlet Cover
RSR00FD-RLO5B	Front Door
RSR00BD-RLO5B	Back Door
RSR00DL-RLO5B	Door Lock
RSR00HB-RLO5B	Handle Bar
RSR00KEY--RLO5B	Key
RSR00RJ-RLO5B	RJ45 Jack
	RJ45 Plug Waterproof Housing
RSR00DR-RLO5B	DIN Rail
RSR00BUS-RLO5B	Positive Busbar
	Negative Busbar
	Grounding Busbar
RSR00SC-RLO5B	Swivel Casters
RSR48FAN-RLO5B	Thermostat Controlled Fans
RSR12IENMC-RLO5B	12AWG 12ft IEC C19 to NEMA 5-20P Power Cable

Your voice matters! Scan the QR code to submit your feedback on the product.



Welcome to join Renogy Power **PLUS** Community by scanning the QR code to install DC Home app. Find your e-warranty here, and more.

